

General Certificate of Conformance

FlameSafe® Firestop Products

FlameSafe® FS1900 Sealant ^{1,2}	FlameSafe® FS3000 Spray ^{1,2}
FlameSafe® FS900+ Sealant ^{1,2}	FlameSafe® FSIS Intumescent Sleeve
FlameSafe® FS900 Sealant ¹	FlameSafe® FSPIL Pillows
FlameSafe® FSM Mortar Seal	FlameSafe® FSB Bags
FlameSafe® FSP1100 Putty	FlameSafe® FS500 / FST600 Sealant ¹
FlameSafe® FSP1077 Putty Pad	FlameSafe® C700+ Elastomeric Spray
FlameSafe® FSP1000 Putty	FlameSafe® C700 Series Coating
FlameSafe® FSWS Wrap Strip	FlameSafe® PB100 Panel Board
FlameSafe® S100 Sealant ¹	FlameSafe® FS 4000 Silicone Sealant ^{1,2}
FlameSafe® FSD Device	FlameSafe® Silicone Sealant ^{1,2}



THESE PRODUCTS COMPLY WITH THE FOLLOWING ASTM STANDARDS:

E 119	Standard Test Methods for Fire Tests of Building Construction and Materials, (UL 263)
E 814	Standard Test Method for Fire Tests of Through-Penetration Fire Stops, (UL 1479/CAN4-S115M)
¹ E 84	Standard Test Method for Surface Burning Characteristics of Building Materials, (UL 723)
² E 1966	Standard Test Method for Fire-Resistive Joint Systems, (UL 2079)
² E 1399	Standard Test Method for Cyclic Movement and Measuring the Minimum and Maximum Joint Widths of Architectural Joint Systems

No asbestos or PCBs are used or contained in these products.

A handwritten signature in black ink, appearing to read "Eva Ackerman".

Eva Ackerman
Vice President, Research and Technology

09/24/09

Date